

ENVIRONMENTAL MONITORING LAB., INC

PH0509

59 N Plains Industrial Road
Wallingford, CT 06492

Saturday, September 5, 2020

Voice: (203) 284-0555

Fax: (203) 284-2064

Email: eml.ct@snet.net

To: Bethany Town Center
44 Peck Road
Bethany, CT 06524

Laboratory Report: Water Quality Testing

Lab Sample Number: 200825BPSA-17739

EDI Batch#: 10544

Coll.Date	Collected By	Facility (Water System)	PWS ID#	Sampling Location	WSF ID	Smp Point
8/25/2020	Burke, Andrew	BETHANY TOWN CENTER	CT0080064	DSR-SCHOOL	00600	4

Laboratory Results

	Laboratory Result	Rptg Units	Lab Rpt Lvl	MCL	Standard Method Code	Analysis Completion Date
Dist Total Coliform (DSTC)						
1012 CHLORINE RESIDUAL	nd < 0.05	MG/L	MRL		4500CL-F	8/25/2020
3100 DISTRIBUTION COLIFORM TOTAL	A				9223B	8/26/2020
3014 DISTRIBUTION E.COLI	A				9223B	8/26/2020
Dist Physical Parameters (PPS)						
1905 DISTRIBUTION COLOR	4	CU	n/a		110.3	8/25/2020
1920 DISTRIBUTION ODOR	0	TON	n/a		2150B	8/25/2020
1925 DISTRIBUTION PH (S.U.)	6.06	PH	n/a		4500H-B	8/25/2020
0100 DISTRIBUTION TURBIDITY	0.35	NTU	n/a		2130B	8/25/2020