

ENVIRONMENTAL MONITORING LAB., INC

PH0509

59 N Plains Industrial Road
Wallingford, CT 06492

Friday, July 5, 2019

Voice: (203) 284-0555
Fax: (203) 284-2064
Email: eml.ct@snet.net

To: Bethany Town Center
44 Peck Road
Bethany, CT 06524

Laboratory Report: Water Quality Testing

Lab Sample Number: 190621BPSC-15661

EDI Batch#: 10490

Coll.Date	Collected By	Facility (Water System)	PWS ID#	Sampling Location	WSF ID	Smp Point
6/21/2019	Burke, Andrew	BETHANY TOWN CENTER	CT0080064	DSR-SCHOOL	00600	4

Laboratory Results

	Laboratory Result	Rptg Units	Lab Rpt Lvl	MCL	Standard Method Code	Analysis Completion Date
Miscellaneous Chemical Analytes (MiscChem)						
1094 ASBESTOS	nd <0.20	MFL	MRL	7	100.2	6/28/2019

59 N Plains Industrial Road
 Wallingford, CT 06492

Friday, July 5, 2019

Voice: (203) 284-0555
 Fax: (203) 284-2064
 Email: eml.ct@snet.net

To: Bethany Town Center
 44 Peck Road
 Bethany, CT 06524

Laboratory Report: Water Quality Testing

Lab Sample Number: 190621BPSA-15666

EDI Batch#: 10490

Coll.Date	Collected By	Facility (Water System)	PWS ID#	Sampling Location	WSF ID	Smp Point
6/21/2019	Burke, Andrew	BETHANY TOWN CENTER	CT0080064	DSR-SCHOOL	00600	4

Laboratory Results

	Laboratory Result	Rptg Units	Lab Rpt Lvl	MCL	Standard Method Code	Analysis Completion Date
Dist Total Coliform (DSTC)						
1012 CHLORINE RESIDUAL	nd < 0.05	MG/L	MRL		4500CL-F	6/21/2019
3100 DISTRIBUTION COLIFORM TOTAL	A				9223B	6/22/2019
3014 DISTRIBUTION E.COLI	A				9223B	6/22/2019
Dist Physical Parameters (PPS)						
1905 DISTRIBUTION COLOR	4	CU	n/a		110.3	6/21/2019
1920 DISTRIBUTION ODOR	0	TON	n/a		2150B	6/21/2019
1925 DISTRIBUTION PH	6.33	PH	n/a		4500H-B	6/21/2019
0100 DISTRIBUTION TURBIDITY	0.57	NTU	n/a		2130B	6/21/2019

2981	1,1,1-TRICHLOROETHANE	nd <0.0005	MG/L	MRL	0.2	524.2	6/22/2019
2985	1,1,2-TRICHLOROETHANE	nd <0.0005	MG/L	MRL	0.005	524.2	6/22/2019
2378	1,2,4-TRICHLOROBENZENE	nd <0.0005	MG/L	MRL	0.07	524.2	6/22/2019
2984	TRICHLOROETHYLENE	nd <0.0005	MG/L	MRL	0.005	524.2	6/22/2019
2414	1,2,3-TRICHLOROPROPANE	nd <0.0005	MG/L	MRL	**	524.2	6/22/2019
2418	1,2,4-TRIMETHYLBENZENE	nd <0.0005	MG/L	MRL	**	524.2	6/22/2019
2424	1,3,5-TRIMETHYLBENZENE	nd <0.0005	MG/L	MRL	**	524.2	6/22/2019
2976	VINYL CHLORIDE	nd <0.0005	MG/L	MRL	0.002	524.2	6/22/2019
2995	XYLENE, META	nd <0.0005	MG/L	MRL	***	524.2	6/22/2019
2997	XYLENE, ORTHO	nd <0.0005	MG/L	MRL	***	524.2	6/22/2019
2962	XYLENE, PARA	nd <0.0005	MG/L	MRL	***	524.2	6/22/2019